

VOC Content Test Certificate

Monday February 15th, 2010

Supplier: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills NSW 2147)

Sample Description: Ardex WPM 615 Sheet Membrane

Date Tested: February 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	
Green Building Council of Australia	Ardex WPM 615 Sheet Membrane
Green Star Office Design V2 IEQ-13	
Green Star Office Interiors V1.1 IEQ-11	
Architectural Sealant 250 grams per Litre	74 grams per Litre
Specification	
Green Building Council of Australia	Ardex WPM 615 Sheet Membrane
Green Star Office Design V3 IEQ-13	
Architectural Sealant 250 grams per Litre	74 grams per Litre



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1001-19