

Emission Test Certificate

Tuesday, November 29th 2016

Supplier: Ardex Australia Pty Ltd (7/20 Powers Road, Seven Hills, NSW 2147)

Sample Description: Ardex WPM 750 (Undertile Butynol)

Date Tested: November 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p>Green Building Council of Australia <i>Green Star Interiors V1.1 - 12.1.2B</i> <i>Green Star Design & As Built V1.1 - 13.1.2B</i></p>	<p>Ardex WPM 750 (Undertile Butynol)</p>
<p>Total Volatile Organic Compound Emission Rate limit: <0.5 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.082 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BEng(Chemical Engineer)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV161145