

# VOC Content Test Certificate

Thursday, August 29<sup>th</sup>, 2013

Manufacturer: Ardex Australia (7/20 Powers Road, Seven Hills, NSW 2147)

Sample Description: Ardex A30

Date Tested: August 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>	<b>Ardex A30</b>
Sub-floor Adhesive  50 grams per Litre as VOC content per material	<b>&lt;1 grams per Litre as VOC content per material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant

**CV130813**