

VOC Content Test Certificate

Tuesday, 12th April 2016

Manufacturer: Ardex Australia Pty Ltd (20 Powers Road, Seven Hills, NSW 2147).

Sample Description: Ardex WR 100

Date Tested: April 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Design & As Built V1.1 13.1.1</p> <p>Green Star Interiors V1.1 12.1.1B</p>	<p>Ardex WR 100</p>
<p>General Purpose Adhesive and Sealants: 50 grams per Litre as VOC content per material</p>	<p><1 grams per Litre as VOC content per material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV160337