

VOC Content Test Certificate

Friday April 13th, 2012

Manufacturer: Ardex Australia (20 Powers Rd, Seven Hills, NSW 2147)

Sample Description: Ardex Multiprime

Date Tested: March 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Ardex Multiprime*
Interior sealer 65 grams per Litre as VOC content per material	14 grams per Litre as VOC content per material

*Calculation based on manufacturers supplied water content



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV120311a