

# VOC Content Test Certificate

Wednesday 5<sup>th</sup> April 2023

Supplier: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills, NSW 2147, Australia)

Sample Description: Ardex Quickbond

Date Tested: March 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b>	<b>Ardex Quickbond</b>
<b>General Purpose Adhesives and Sealants Limit:</b> <b>50 grams per litre</b>	<b>1 gram per litre as VOC content per material</b>
<b>Meets GBCA VOC Content Requirement</b>	<b>Yes</b>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant



Dr. Tuan Duong  
 PhD, BE (Chem. Eng.)  
 Senior Consultant



Travis Hale  
 BSc (Biotechnology)  
 Senior Consultant

Issue date: 23/04/2023

Expiry date: 23/04/2028

P23020085