

# VOC Content Test Certificate

Wednesday, 8<sup>th</sup> August 2018

Supplier: Ardex Australia Pty Ltd (7/20 Powers Road, Seven Hills, NSW, 2147, Australia).

Sample Description: Ardex WPM 717 Grey

Date Tested: August 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

**Test Data:**

<p><b>Specification</b></p> <p><b>Green Building Council of Australia</b></p> <p><b>Green Star Design &amp; As Built V1.1 13.1.1</b></p> <p><b>Green Star Interiors V1.1 12.1.1B</b></p>	<p><b>Ardex WPM 717 Grey</b></p>
<p>Waterproofing membranes and sealant: 250 grams per Litre as VOC content per material</p>	<p><b>2 grams per Litre as VOC content</b></p>
<p><b><i>We hereby certify Ardex WPM 717 Grey is well below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></b></p>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

**CV180834**